

Northumbria Historic Churches Trust



Registered Charity No 511314
www.northumbriahct.org.uk

CONDITIONS OF GRANT OFFER FOR ELECTRICAL REWIRING

(A) The rewiring must be done in:

mineral-insulated metal-sheathed (MICC) cables to BS 60702 *OR*
cables drawn into steel conduit or trunking *OR*
cables drawn into heavy gauge high impact plastic conduit to BS 4607 *OR*
electric cables to ONE of the following: BS 7211, BS 7629, BS 7846

as directed by the architect, and must be installed by a contractor approved by the NICEIC, or a registered member of the ECA or NAPIT.

(B) For the purposes of Standard Condition 7a) in respect of electrical work, you should send us a copy of the signed first page of the Electrical Installation Certificate issued in accordance with BS 7671.